

**Memorial Villages Water Authority
Local Effluent Discharge Limits
Not to Exceed**

Metal	Average (mg/L)	Daily Comp (mg/L)	Grab Sample (mg/L)
Arsenic	0.1	0.2	0.3
Barium	1.0	2.0	4.0
Cadmium	0.05	0.1	0.2
Chromium	0.5	1.0	5.0
Copper	0.5	1.0	2.0
Lead	0.5	1.0	1.5
Manganese	1.0	2.0	3.0
Mercury	0.005	0.005	0.01
pH			5.5 min - 9.5 max
Nickel	1.0	2.0	3.0
Selenium	0.05	0.1	0.2
Silver	0.05	0.1	0.2
Zinc	1.0	2.0	6.0

Note: These concentration parameters and rules governing same are promulgated under authority of Sections 5.131 and 5.132, Texas Water Code - HAZARDOUS METALS and in accordance with Texas Commission on Environmental Quality Rule 156.19.